



Maharashtra Government
DISTRICT PUBLIC HEALTH LABORATORY, NASHIK

Office Phone No.:- 0253 - 2570613

Email Id:- dphlnasik@gmail.com

Office:- - Junior Scientific Officer District Public Health,
Laboratory, Civil Hospital Campus, Trimbak Road, Nashik -
422 001.

NO. DPHL/NSK/WC/ W-159/ 3731 /2024

Date:- 01/08 /2024

Health Services

REPORT ON CHEMICAL EXAMINATION OF WATER FOR DRINKING PURPOSES

Date of Collection- ----- Date of receipt -24/07/2024 Date of Examination-24/07/2024 & onwards
Letter No.EHS/P/29/2024-25 Dated: 24/07/24

Analytical results in mg/litre (except pH& turbidity)

Sr. No.	Name of Test	Results	BIS Specification 10500:2012	
			Normal values	
		1	Desirable limits	Permissible limits
	Source	Bore well with pump	-----	-----
01	Physical appearance	Clear, Colorless	-----	-----
02	Odor	Odorless	Agreeable	Agreeable
03	pH	7.35	6.5 to 8.5	No relaxation
04	Turbidity (NTU)	0.10	1.0	5.0
05	Chlorides	31.53	250	1000
06	Total Hardness	92	200	600
07	Total alkalinity	89.28	200	600
08	Total dissolved solids	175	500	2000
09	Fluoride	0.08	1.0	1.5
10	Iron	0.107	0.3	No relaxation
11	Nitrates	4.00	45	No relaxation
12	Permanent hardness	2.72	-----	-----

Remark:- The above sample no. 01 is chemically fit for drinking purpose on the basis of analyzed parameters only. However, this water source can be used for drinking purpose only after proper treatment, disinfection and ascertaining their bacteriological quality frequently or regularly.

Forwarded with compliments to:
Espalier Heritage School,
Trimbak Road,
Nashik.

R.No.-5145823, Rs.600/-, Dt-24/07/2024

B. B. B. B.
Junior Scientific Officer
District Public Health Laboratory,
Nashik.

P. B. B. B.
MANAGER
ESPALIER HERITAGE SCHOOL, NASHIK

S. B. B. B.
PRINCIPAL
ESPALIER HERITAGE SCHOOL



महाराष्ट्र शासन सार्वजनिक आरोग्य सेवा
प्राथमिक आरोग्य केंद्र जातेगाव
ता. जि. नाशिक



0253 - 2989111 ✉ mojategaon@gmail.com

जावक क्र. 135

दि. 9/6/25

SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

This is to certify that I have visited Espalier Heritage School, near trambak vidya mandir, Belgaon dhaga, Nashik Maharashtra, Pin Code-422213 on 06-06-2025. The team inspected drinking water and hygiene and sanitation facilities of the campus. It is found that no any abnormalities are at present inspection and hence drinking water and hygiene and sanitation facilities are safe for the students and all staff members.

This certificate is issued for official purpose.



Handwritten signature
Medical Officer Gr-A
P.H.C. Jategaon, Tal. Dist. Nashik

Handwritten signature

MANAGER
ESPLALIER HERITAGE SCHOOL, NASHIK

Handwritten signature

PRINCIPAL
ESPLALIER HERITAGE SCHOOL